

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-22-05-17-01

Products: Classen - laminate floorings (acc. to EN 13329:2016+A1:2017)
Thicknesses: 6 mm - 12 mm

Producer: Classen Industries GmbH
An der Birkenpfehlheide 6
15837 Baruth

Order: Determination of the electrostatic behaviour according to EN 1815:2016 /
Classification according to EN 14041:2004+AC:2005+AC:2006

Test reports: 2721320/A1, 2722219

Test results: Classen laminate floorings (acc. to EN 13329) can be classified regarding to the
property "Electrostatic behavior" according to EN 14041:2004+AC:2005+AC:2006
(CE-labelling) as follows:

Property	Determined values	Declaration according to EN 14041:2004+AC:2005+AC:2006
Body voltage in walking test according EN 1815:2016	0,1 - 0,3 kV	Antistatic floor covering

Dresden, 17/05/2022



[Signature]

Head of laboratory

[Signature]

Engineer in charge